

LEYLAND
1-16 THE GRANGE
THE GRANGE
OLD ST
WIDNES WA8 8QT

06 MAY 2020



Developed and implemented by:

Leyland Forrest Building Services
Unit 1 Delta House
Wrigley St, Oldham
OL4 1SL
<https://leylandforrest.co.uk/>

SURVEY - MULTIPLE SEALS - SEAL DETAILS

Seal Id	5
FS/AS	60 Minutes
Level	Ground
Location	Water meter riser
Is an access panel required? complete	No
	http://www.bing.com/maps/default.aspx?v=2&cp=53.362682~-2.759827&lvl=16&sp=point.53.362682_-2.759827_ Location given by network reading

SEAL TYPE

Seal type	High Expansion Intumescent Mastic Mastic Joints
X	50 8000
Y	50 25
Number of other identical seals	9 0

Penetrating Service	Plastic Pipe None
Comments	Apply intumescent mastic to all pipes. Apply intumescent mastic to perimeter joints





SURVEY - MULTIPLE SEALS - SEAL DETAILS

Seal Id	4
FS/AS	60 Minutes
Level	Ground
Location	Entrance corridor/stairwell
Is an access panel required? complete	No http://www.bing.com/maps/default.aspx?v=2&cp=53.362621~-2.759732&lvl=16&sp=point.53.362621_-2.759732_ Location given by network reading

SEAL TYPE

Seal type	Intumescent putty rope Intumescent putty pads
X	200 1
Y	200 1
Number of other identical seals	5 0

Penetrating Service Comments	Cable 4 x lights, putty rope 1 x smoke alarm, putty rope 1 x motion sensor, putty rope 1 x double socket, putty pad. ALL ITEMS WILL NEED ISOLATING AND COVERS REMOVING TO CARRY OUT WORKS
---------------------------------	---



